Backup Electric Supply

DG SET DETAILS

Following are the 15 KVA DG set details-

- Location of DG set –Institution Building

- Set details
  - Module :CDB100153D22
  - Rating :15 KVA
  - P.F :0.8 Phase 3
  - Voltage :4.15V
  - Current :20.9AMP
  - Frequency :50Hz
  - Noise Limit at 1 MTR :75dBA
  - Approval Certificate number : ⟶ ARAI/DGTA/CCPL/CDB100203D22/2014/4450

Dr. KY Reddy

Director

DIRECTOR
Padmashree Institute of Management and Sciences
Bengaluru-560 060

Scanned with OKEN Scanner