



## Backup Electric Supply

### DG SET DETAILS

Following are the 15 KVA DG set details-

➤ Location of DG set –Institution Building

➤ Set details

- Module :CDB100153D22
- Rating :15 KVA
- P.F :0.8 Phase 3
- Voltage :4.15V
- Current :20.9AMP
- Frequency :50Hz
- Noise Limit at 1 MTR :75dBA
- Approval Certificate number : \_\_\_\_\_  
ARAI/DGTA/CCPL/CDB100203D22/2014/4450

Director

**DIRECTOR**

**Padmashree Institute of Management and Sciences**  
**Bengaluru-560 060**

GOVINDAPPA SHIVAPRASAD  
D  
Digitally signed  
by GOVINDAPPA  
SHIVAPRASAD  
Date: 2024.11.30  
14:59:10 +05'30'

